

CITY OF FORT PIERRE

ANNUAL WATER QUALITY REPORT

January 2001 to December 2001

Introduction.

The purpose of this report is to inform water users of the quality of the drinking water. The city is required by the U.S. Environmental Protection Agency (EPA) to test the water frequently for the presence and concentration level of many different substances. The South Dakota Department of Environment and Natural Resources (DENR) reviews all of our testing data to ensure that 1.) we are providing safe drinking water to our customers, and 2.) we are complying with EPA regulations.

The city wants all readers to fully understand the information contained in this report. If any questions arise, please contact:

Brad Lawrence
Director of Public Works
P.O. Box 700
Fort Pierre, SD 57532
Phone: (605) 223-7690
Fax: (605) 223-7693
BradL.cityftierre@midconetwork.com

Where does Fort Pierre's water come from?

The city serves nearly 2,000 persons and 200 businesses with an average of 402,487 gallons of water per day. The water is supplied from two active water wells and one inactive water well located along the Missouri River. The two active water wells are sunk approximately 65 feet into an underground aquifer. One well is near the HUSTAN site next to the river while another well is near Shimrose Drive next to the river. The inactive well is at the end of Seventh Ave. near the river. The state is performing an assessment of our source water that will be available in May 2003.

Why do we test our drinking water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and can pick up substances resulting from the presence of animals or from human activity. Too much of any substance, either naturally occurring or resulting from human activities, can be considered a contaminant.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, or runoff from mining or farming activities.

Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, and septic systems.

Radioactive contaminants, which are naturally occurring in some of the rocks in this region.

Information provided by the EPA.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

Definition of Terms.

The following definitions are provided to assist the reader in understanding the city's water quality test results and the following discussion of the results.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCL-Gs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCL-Gs allow for a margin of safety

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Table of Detected Contaminants

Substance	Level Detected	Ideal Goals (MCLG)	Highest Level Allowed (MCL)	Likely Source of Substance
<i>Regulated Contaminants</i>				
Arsenic	2.3	NA	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronic production wastes
Barium	.068	2	2	Erosion of natural deposits; Discharge of drilling wastes; discharge from metal refineries
Fluoride	1.87	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer factories
Copper	.81 - #Sites>1.3 AL-1	0	AL=1.3	Corrosion of Household Plumbing Systems; Erosion of Natural Deposits
Lead	8.8 - #Sites>15 AL-1	0	AL=15	Corrosion of Household Plumbing Systems; Erosion of Natural Deposits
Total Coliform Bacteria	1	0	1	Naturally present in the environment
Alpha emitters	.3	0	15	Erosion of natural deposits

1. All monthly measurements were in compliance.
2. The table lists all the drinking water contaminants data that were detected and tested during the calendar year 2001 with the exception of copper and lead, which was previously tested in 2000. The presence of the contaminants in the water does not necessarily indicate that the water poses a health risk.
3. The state allows us to test for some substances less than once per year because the concentrations of these substances do not change frequently. Some of our data, though representative of the water quality, is more than one year old.

2001 Water Quality Tests Results.

Our water is routinely tested for many different substances. Of those substances, only those seven substances listed in the above table were detected; however the substances were below the Highest Level Allowed by the EPA with the sole exception of one Total Coliform Bacteria test. Monitoring and reporting violations do not necessarily indicate a health risk. However, since levels of this parameter was not monitored the potential health risk posed by this contaminant may not be known.

Lead and Copper does not come from water supplied by the city, but is derived from home plumbing fixtures. Again, lead and copper levels were well below the Highest Level Allowed by EPA. Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in Fort Pierre as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

Arsenic, barium, fluoride, and alpha emitters are naturally occurring substances and were below both the Ideal Goal and Highest Level Allowed, which indicates safe levels. Arsenic, barium, and fluoride are substances that may be derived from the discharge of certain types of manufacturing or agriculture, but the city's test results were below both the Ideal Goal and Highest Level Allowed, which indicates safe levels.

Your Input is Welcomed!

The city encourages all customers to attend and participate in the meetings of the Fort Pierre Common Council. The Council meets on the first and third Monday of each month at the Stanley County Courthouse at 7:30 p.m. If any questions arise regarding these meetings, please contact:

David Page
 City Finance Officer
 PO Box 700
 Fort Pierre, S.D. 57532
 Phone: (605) 223-7690
 Fax: (605) 223-7693
 DavidP.cityftPierre@midconetwork.com

